

## ADDENDUM #2

Date: March 16, 2018

This Addendum applicable to work designated herein shall be understood to be and is an Addendum and as such shall be part of and included in the Contract.

To all bidders for furnishing all labor and materials necessary for:

### **Rigby Pioneer Cemetery New Maintenance Building**

Failure to acknowledge receipt of this Addendum on the bid proposal form may result in rejection of your bid.

Addendum consists of: 1 page. Attached Documents consist of - N/A

**Bid Opening Date:** March 20, 2018  
**Time:** 2:00 p.m.  
**Location:** NBW Architect's Office  
990 John Adams, Pkwy  
Idaho Falls, Idaho 83401

### MECHANICAL ITEMS

1. Sheet MP-2: Plumbing Fixture Schedule. WC-1, Delete Reference to Sloan Regal Flush Valve and 1 1/4" P-Trap. Not required.

### ELECTRICAL ITEMS

1. Contractor shall stub 4" dia. Electrical conduit from main electrical panel to exterior of building to accommodate the Owner supplied electrical service. The service will enter the building from the south wall of the mechanical room.
2. Light Fixtures are to be surface mount as specified.

END OF ADDENDUM NO.1